

Metering Requirements

Scope

This document outlines the requirements, responsibilities, and guidelines for the installation, identification, and maintenance of electric metering equipment. It applies to all service types including residential, commercial, and primary metering buildings. These requirements are applicable to both new construction and existing service modifications.

General Metering Requirements

Customers are required to supply a Company-approved, self-contained meter socket for services rated at 400 amps or smaller. For services greater than 400 amps, C.T. rated metering or primary metering is required. A minimum capacity of 200 amps is required for all single position meters. Approved models can be found on the Company website or obtained through Customer Service. Any metering practices not explicitly listed in this standard, including but not limited to transformer metering and switchgear metering, shall not be permitted for new construction. All configurations not included in the Electric Service Standards must be approved by a Standards Representative.

Metered and unmetered conductors shall not be installed in the same conduits or raceways. Unmetered service conductors shall not be permitted to exit metering equipment. Metering socket shall not be used as a raceway for feeder circuits per NEC 230.7. Disconnects on the source side of the meter are generally prohibited, except where permission is granted in the standard or the AHJ. Tampering with Company property, including breaking seals, is strictly prohibited and may be subject to legal penalties and fees. The meter pulling process defined by the Company is not considered tampering (for use only in EKC).

Meter Location Requirements

Customers must contact a Company Representative to verify meter location prior to installation. Meter locations must be accessible, meaning capable of being reached for operation, renewal, and inspection. Unapproved installations may result in denial of service. Meters must be installed on the exterior side of the building closest to Company facilities and should avoid areas exposed to vibration, gases, dust, fluids, or vehicular traffic.

Meter Collar Requirements

Evergy allows the use of certain approved meter collars for solar installations.

Approved Equipment

Only meter collars listed on Evergy’s Approved Meter Collar List may be used.

Meter collars are permitted only for customers meeting these criteria:

- Residential single occupant service
- 200A single-phase service, and
- One (1) meter collar device per customer.

Customer Responsibilities

Contact Evergy to schedule a service request prior to meter collar installation.

If a meter socket upgrade is required:

- Customer must perform all necessary work before the meter collar installation.

The customer is responsible for:

- Providing clear socket blanks
- Providing meter socket rings

Electrician Responsibilities

A licensed electrician must be present to install the meter collar on the meter socket.

Evergy personnel will remove and reinstall the meter as required for the work.

Evergy Authority & Limitations

Evergy reserves the right to pull the meter during outages or for safety-related concerns.
Evergy is not responsible for reinstalling the meter collar following removal.
If reinstallation is required, the customer must contact Evergy to schedule another service request.

Multiple Meter Installations

It is the responsibility of the building owner, customer, or their agent to ensure proper wiring to the correct meter, correct any mismarked switches or enclosures, and be present during Company verification. The Company will not activate service until all markings and connections are verified and confirmed to be correct.

C.T. Rated Metering

C.T. rated metering is required for services exceeding 400 amps for both single-phase and three-phase installations. C.T. rated metering is allowed for services less than 400 amps only when jurisdiction requires the Company to do so, and it is serving a fire pump.

Internal Metering

Internal metering is allowed for buildings with four or more floors, but only with prior Company approval. Meters must be consolidated in a common meter room or placed on every second or third floor. The Company must have 24/7 access to these rooms. An antenna may be required to ensure reliable meter communication. Customers is always required to provide all necessary conduit pathways and mounting provisions during construction, regardless of whether an antenna is ultimately installed. These provisions greatly reduce the cost of future antenna installation if communication issues arise. The cost of installation is the responsibility of the customer. These rooms must have exterior walls and meet all clearance and egress standards.

- A single entrance to and egress from the required working space shall be permitted where unobstructed egress or extra working space is provided.
 - a. Unobstructed egress shall be defined as a clear exit away from the working space.
 - b. Extra working space shall be defined as clearance that is double Evergy minimum clearances (8 feet is required for internal meters less than 600 Volts).
- A second means of egress may be provided to ensure unobstructed egress.

Meter Communication & Antenna

- Conduit Requirements:
 - One 2-inch conduit from each meter room to the common meter room.
 - From common meter room, one 2-inch conduit to an exterior point (15–35 ft above ground, ≤80 ft length).
 - Max 3 bends per conduit (two vertical 90°, one horizontal ≤90°).
- Provide:
 - Flat mounting surface for antennas.
 - Weather-head on exterior conduit.
 - Space for up to 2 interior antennas and 3 exterior antennas.
 - 2 ft × 3 ft interior wall space for RF transceivers.
 - 120 V / 15 A receptacle in each meter room.
- Documentation:
 - Proposed meter room locations must be shown on the riser diagram submitted with the service application.

Contact a Company Representative with questions.

Electric Vehicle (EV) Metering

The Company requires that EV chargers wanting access to the Separately Metered EV Time of Use rate be metered utilizing a two-position meter socket. In instances where the customer cannot install a two-position meter socket, they must reach out to a Standards Representative to review alternative options. This only applies to EMM and EMW.

Service	Manufacturer	Part Number	Kit	Service Application
3W 200 AMP	DURHAM	1010291		RSFO, RSFU, RMFO, RMFU
3W 200 AMP	DURHAM	T-H5213B		CSOO, CSOU, CMFO, CMFU
3W 200 AMP	EATON	1010291CH		RSFO, RMFO
3W 200 AMP	EATON	MBXB150BTS		CSOO, CMFO
3W 200 AMP	EATON	MBXB200BTS		CSOO, CMFO
3W 200 AMP	EATON	MBXP200BTS		CSOO, CMFO
3W 200 AMP	EATON	UGHTRS233CCH		RSFO, RMFO
3W 200 AMP	EATON	UTE5213CCH		CSOO, CMFO
3W 200 AMP	MILBANK	U6281-XL-100-IL-5T9W-EV E		CSOO, CSOU, CMFO, CMFU
3W 200 AMP	MILBANK	U6281-XL-150-IL-5T9W-EV E		CSOO, CSOU, CMFO, CMFU
3W 200 AMP	MILBANK	U6281-XL-200-IL-5T9W-EV E		CSOO, CSOU, CMFO, CMFU
3W 200 AMP	MILBANK	U7043-XL-TG-KK-IL-5T9W		RSFO, RSFU, RMFO, RMFU
3W 200 AMP	TALON	48805-0BNU		CSOO, CSOU, CMFO, CMFU
3W 200 AMP	TALON	UAT817-XVZKCPL		RSFO, RMFO
3W 400 AMP	DURHAM	UG-H4300U-KC		RSFO, RSFU, RMFO, RMFU, CSOO, CSOU, CMFO, CMFU
3W 400 AMP	EATON	UG-H4300U-KCCH		CSOO, CMFO
3W 400 AMP	MILBANK	U2448-X-5T9-K3-K2-IL		RSFO, RSFU, RMFO, RMFU, CSOO, CSOU, CMFO, CMFU
3W 400 AMP	MILBANK	U4702-X-5T9-K3-K2-IL		RSFO, RSFU, RMFO, RMFU, CSOO, CSOU, CMFO, CMFU
3W 400 AMP	TALON	47705-82KCPL		RSFO, RMFO, CSOO, CMFO
4W 200 AMP	DURHAM	U-H7213C-KC		CSOO, CSOU, CMOO, CMOU
4W 200 AMP	EATON	U-H7213C-KCCH		CSOO, CMOO
4W 200 AMP	EATON	UTH7213UCH		CSOO, CMOO
4W 200 AMP	MILBANK	U9701-XL-IL-EVE		CSOO, CSOU, CMOO, CMOU
4W 200 AMP	TALON	40607-025		CSOO, CSOU, CMOO, CMOU
4W 400 AMP	EATON	UTH7330UCH		CSOO, CMOO
4W 400 AMP	EATON	UTH73369UHLCH		CSOO, CMOO
4W 400 AMP	MILBANK	U4013-X-2/K7-IL		CSOO, CSOU, CMOO, CMOU
4W 400 AMP	TALON	48707-02		CSOO, CSOU, CMOO, CMOU

Service	Manufacturer	Part Number	Kit	Service Application	Status Date	Comments
3W 200 AMP	DURHAM	1010291		CSOO, CSOU, CMFO, CMFU	10/3/2026	
3W 200 AMP	EATON	UGHTRS233CCH		CSOO, CMFO	10/3/2026	
3W 200 AMP	MILBANK	U7043-XL-TG-KK-IL-5T9W		CSOO, CSOU, CMFO, CMFU	10/3/2026	
3W 200 AMP	TALON	UAT817-XVZKCPL		CSOO, CSOU, CMFO, CMFU	10/3/2026	

Service	Manufacturer	Part Number	Kit	Service Application
3W 200 AMP	ConnectDER	Solar MSA		RSFO, RSFU



Service	Manufacturer	Part Number	Kit	Service Application
3W 200 AMP	ConnectDER	Solar MSA		RSFO, RSFU

Service	Manufacturer	Part Number	Kit	Service Application

Service	Manufacturer	Part Number	Kit	Service Application
3W 200 AMP	MILBANK	U5168-XL-100-KK-IL-5T9W-EV E		RSFO, RSFU, RMFO, RMFU, CSOO, CSOU, CMFO, CMFU, CMOO, CMOU
3W 200 AMP	MILBANK	U5168-XL-150-KK-IL-5T9W-EV E		RSFO, RSFU, RMFO, RMFU, CSOO, CSOU, CMFO, CMFU, CMOO, CMOU
3W 200 AMP	MILBANK	U5168XL200KKIL5T9WEVE		RSFO, RMFO, CSOO, CMFO, CMOO
3W 200 AMP	MILBANK	U5168-XL-200-KK-IL-5T9W-EV E		RSFO, RSFU, RMFO, RMFU, CSOO, CSOU, CMFO, CMFU, CMOO, CMOU
3W 400 AMP	MILBANK	U6227-X-400-K3L-IL-5T9W-EV E		RSFO, RSFU, RMFO, RMFU, CSOO, CSOU, CMFO, CMFU, CMOO, CMOU
3W 400 AMP	MILBANK	U6229-X-400-K7L-IL-EVE		RSFO, RSFU, RMFO, RMFU, CSOO, CSOU, CMFO, CMFU, CMOO, CMOU
3W 400 AMP	MILBANK	U6585X2200K3L5T9WILEVE		RSFO, RMFO, CSOO, CMFO, CMOO
3W 400 AMP	MILBANK	U6601-X-2/200-K3L-5T9-EVE		RSFO, RSFU, RMFO, RMFU, CSOO, CSOU, CMFO, CMFU, CMOO, CMOU
3W 400 AMP	MILBANK	U6602-X-2/200-K3L-5T9-EVE		RSFO, RSFU, RMFO, RMFU, CSOO, CSOU, CMFO, CMFU, CMOO, CMOU
3W 400 AMP	MILBANK	U6603-X-2/200-K3L-5T9-EVE		RSFO, RSFU, RMFO, RMFU, CSOO, CSOU, CMFO, CMFU, CMOO, CMOU

Service	Manufacturer	Part Number	Kit	Service Application	Status Date	Comments
3W 200 AMP	MILBANK	U5168XL200KKIL5T 9WEVE		CMFU, CMOU	9/30/2026	
3W 200 AMP	SIEMENS	MC0816B1100RJBT		CSOU, CMFU	4/13/2027	
3W 200 AMP	SIEMENS	MC0816B1150RJBT		CSOU, CMFU	4/13/2027	
3W 200 AMP	SIEMENS	MC0816B1200RJBT		CSOU, CMFU	4/13/2027	
3W 400 AMP	MILBANK	U5059-X-2-200-K3L-I L-5T9W-EVE		RSFO, RSFU, RMFO, RMFU, CSOO, CSOU, CMFO, CMFU, CMOO, CMOU	4/13/2027	
3W 400 AMP	MILBANK	U5890-X-2-200-K3L-I L-5T9W-EVE		RSFO, RSFU, RMFO, RMFU, CSOO, CSOU, CMFO, CMFU, CMOO, CMOU	4/13/2027	
3W 400 AMP	MILBANK	U5891-X-2-200-K3L-I L-5T9W-EVE		RSFO, RSFU, RMFO, RMFU, CSOO, CSOU, CMFO, CMFU, CMOO, CMOU	4/13/2027	
3W 400 AMP	MILBANK	U5892-X-2-200-K3L-I L-5T9W-EVE		RSFO, RSFU, RMFO, RMFU, CSOO, CSOU, CMFO, CMFU, CMOO, CMOU	4/13/2027	
3W 400 AMP	MILBANK	U6115-X-2-200-K7L-I L-EVE		RSFO, RSFU, RMFO, RMFU, CSOO, CSOU, CMFO, CMFU, CMOO, CMOU	4/13/2027	
3W 400 AMP	MILBANK	U6585X2200K3L5T9 WILEVE		RSFU, RMFU, CSOU, CMFU, CMOU	9/30/2026	

Service	Manufacturer	Part Number	Kit	Service Application
3W 200 AMP	MILBANK	U2872-Xt-5T9-K4		RMFO, RMFU, CMFO, CMFU, CMOO, CMOU
3W 200 AMP	MILBANK	U2873-Xt-5T9-K4		RMFO, RMFU, CMFO, CMFU, CMOO, CMOU
3W 200 AMP	MILBANK	U2874-Xt-5T9-K4		RMFO, RMFU, CMFO, CMFU, CMOO, CMOU
3W 200 AMP	MILBANK	U2875-Xt-5T9-K4		CMFO, CMFU, CMOO, CMOU
3W 200 AMP	MILBANK	U2876-Xt-5T9-K4		CMFO, CMFU, CMOO, CMOU
3W 200 AMP	MILBANK	U5882-X-KK-K4-5T-KCPL		RMFO, RMFU, CMFO, CMFU, CMOO, CMOU
3W 200 AMP	MILBANK	U5883-X-KK-K4-5T-KCPL		RMFO, RMFU, CMFO, CMFU, CMOO, CMOU
3W 200 AMP	MILBANK	U5884-X-KK-K4-5T-KCPL		RMFO, RMFU, CMFO, CMFU, CMOO, CMOU
3W 200 AMP	MILBANK	U5885-X-KK-K4-5T-KCPL		CMFO, CMFU, CMOO, CMOU
3W 200 AMP	MILBANK	U5886-X-KK-K4-5T-KCPL		CMFO, CMFU, CMOO, CMOU
3W 200 AMP	MILBANK	U5902-X-KK-K4-5T-KCPL		RMFO, RMFU, CMFO, CMFU, CMOO, CMOU
3W 200 AMP	MILBANK	U5903-X-KK-K4-5T-KCPL		RMFO, RMFU, CMFO, CMFU, CMOO, CMOU
3W 200 AMP	MILBANK	U5904-X-KK-K4-5T-KCPL		RMFO, RMFU, CMFO, CMFU, CMOO, CMOU
3W 200 AMP	MILBANK	U5905-X-KK-K4-5T-KCPL		CMFO, CMFU, CMOO, CMOU
3W 200 AMP	MILBANK	U5906-X-KK-K4-5T-KCPL		CMFO, CMFU, CMOO, CMOU
3W 200 AMP	MILBANK	U5972-Xt-5T9-BL-K4		RMFO, RMFU, CMFO, CMFU, CMOO, CMOU
3W 200 AMP	MILBANK	U5973-Xt-5T9-BL-K4		RMFO, RMFU, CMFO, CMFU, CMOO, CMOU
3W 200 AMP	MILBANK	U5974-Xt-5T9-BL-K4		RMFO, RMFU, CMFO, CMFU, CMOO, CMOU
3W 200 AMP	MILBANK	U5975-Xt-5T9-BL-K4		CMFO, CMFU, CMOO, CMOU
3W 200 AMP	MILBANK	U5976-Xt-5T9-BL-K4		CMFO, CMFU, CMOO, CMOU
3W 200 AMP	TALON	UA2311-XB		RMFO, CMFO, CMFU, CMOO, CMOU
3W 200 AMP	TALON	UA2716-ZB		RMFO, CMFO, CMFU, CMOO, CMOU
3W 200 AMP	TALON	UA3311-XB		RMFO, CMFO, CMFU, CMOO, CMOU
3W 200 AMP	TALON	UA3717-ZB		RMFO, CMFO, CMFU, CMOO, CMOU
3W 200 AMP	TALON	UA4311-XB		RMFO, CMFO, CMFU, CMOO, CMOU
3W 200 AMP	TALON	UA4719-ZB		RMFO, CMFO, CMFU, CMOO, CMOU
3W 200 AMP	TALON	UA5719-MB		CMFO, CMFU, CMOO, CMOU
3W 200 AMP	TALON	UA6719-MB		CMFO, CMFU, CMOO, CMOU

Service	Manufacturer	Part Number	Kit	Service Application	Status Date	Comments
3W 200 AMP	DURHAM	UG-2R2332U-KC		RMFO, RMFU, CMFO, CMFU, CMOO, CMOU	4/13/2027	
3W 200 AMP	DURHAM	UG-2R5332C-KC		RMFO, RMFU, CMFO, CMFU, CMOO, CMOU	4/13/2027	
3W 200 AMP	DURHAM	UG-3R1121C-KC		RMFO, RMFU, CMFO, CMFU, CMOO, CMOU	4/13/2027	
3W 200 AMP	EATON	UG-2R2332U-KCCH		RMFO, RMFU, CMFO, CMFU, CMOO, CMOU	4/13/2027	
3W 200 AMP	EATON	UG-2R5332C-KCCH		CMFU, CMOU	4/13/2027	
3W 200 AMP	MILBANK	U1232-X-5T-K1		RMFO, RMFU, CMFO, CMFU, CMOO, CMOU	4/13/2027	
3W 200 AMP	MILBANK	U1233-X-5T-K3		RMFO, RMFU, CMFO, CMFU, CMOO, CMOU	4/13/2027	
3W 200 AMP	MILBANK	U1234-X-5T-K3		RMFO, RMFU, CMFO, CMFU, CMOO, CMOU	4/13/2027	
3W 200 AMP	MILBANK	U1252-X-5T-K1		RMFO, RMFU, CMFO, CMFU, CMOO, CMOU	4/13/2027	
3W 200 AMP	MILBANK	U1253-X-5T-K1		RMFO, RMFU, CMFO, CMFU, CMOO, CMOU	4/13/2027	
3W 200 AMP	MILBANK	U1254-X-5T-K4		RMFO, RMFU, CMFO, CMFU, CMOO, CMOU	4/13/2027	
3W 200 AMP	MILBANK	U1255-X-5T-K4		CMFO, CMFU, CMOO, CMOU	4/13/2027	
3W 200 AMP	MILBANK	U1256-X-5T-K4		CMFO, CMFU, CMOO, CMOU	4/13/2027	
3W 200 AMP	MILBANK	U2852-X-KK-5T		RMFO, RMFU, CMFO, CMFU, CMOO, CMOU	4/13/2027	
3W 200 AMP	MILBANK	U2853-X-KK-5T		RMFO, RMFU, CMFO, CMFU, CMOO, CMOU	4/13/2027	
3W 200 AMP	MILBANK	U2854-X-KK-5T		RMFO, RMFU, CMFO, CMFU, CMOO, CMOU	4/13/2027	
3W 200 AMP	MILBANK	U2855-X-KK-5T		CMFO, CMFU, CMOO, CMOU	4/13/2027	
3W 200 AMP	MILBANK	U2856-X-KK-5T		CMFO, CMFU, CMOO, CMOU	4/13/2027	
3W 200 AMP	MILBANK	U2862-X-KK-5T		RMFO, RMFU, CMFO, CMFU, CMOO, CMOU	4/13/2027	
3W 200 AMP	MILBANK	U2863-X-KK-5T		RMFO, RMFU, CMFO, CMFU, CMOO, CMOU	4/13/2027	
3W 200 AMP	MILBANK	U2864-X-KK-5T		RMFO, RMFU, CMFO, CMFU, CMOO, CMOU	4/13/2027	
3W 200 AMP	MILBANK	U2865-X-KK-5T		CMFO, CMFU, CMOO, CMOU	4/13/2027	
3W 200 AMP	MILBANK	U2866-X-KK-5T		CMFO, CMFU, CMOO, CMOU	4/13/2027	
3W 200 AMP	TALON	UA2311-XB		RMFU	10/4/2026	
3W 200 AMP	TALON	UA2716-ZB		RMFU	9/30/2026	
3W 200 AMP	TALON	UA3311-XB		RMFU	10/4/2026	
3W 200 AMP	TALON	UA3717-ZB		RMFU	9/30/2026	
3W 200 AMP	TALON	UA4311-XB		RMFU	10/4/2026	
3W 200 AMP	TALON	UA4719-ZB		RMFU	9/30/2026	

Service	Manufacturer	Part Number	Kit	Service Application
3W 200 AMP	ABB	RMS28212HHBR		CMFU, CMOU
3W 200 AMP	ABB	RMS28212LHBR		CMFU, CMOU
3W 200 AMP	ABB	RMS28222HHBR		CMFU, CMOU
3W 200 AMP	ABB	RMS28222LHBR		CMFU, CMOU
3W 200 AMP	ABB	RMS28312HHBR		CMFU, CMOU
3W 200 AMP	ABB	RMS28312LHBR		CMFU, CMOU
3W 200 AMP	ABB	RMS28322HHBR		CMFU, CMOU
3W 200 AMP	ABB	RMS28322LHBR		CMFU, CMOU
3W 200 AMP	ABB	RMS28412HHBR		CMFU, CMOU
3W 200 AMP	ABB	RMS28412LHBR		CMFU, CMOU
3W 200 AMP	ABB	RMS28422HHBR		CMFU, CMOU
3W 200 AMP	ABB	RMS28422LHBR		CMFU, CMOU
3W 200 AMP	ABB	RMS28512HHBR		CMFU, CMOU
3W 200 AMP	ABB	RMS28512LHBR		CMFU, CMOU
3W 200 AMP	EATON	37MM120R12		CMFU, CMOU
3W 200 AMP	EATON	37MM220R12		CMFU, CMOU
3W 200 AMP	EATON	37MM320R12		CMFU, CMOU
3W 200 AMP	EATON	3MM212RRLB		CMFU, CMOU
3W 200 AMP	EATON	3MM220RRLB		CMFU, CMOU
3W 200 AMP	EATON	3MM312RRLB		CMFU, CMOU
3W 200 AMP	EATON	3MM320RRLB		CMFU, CMOU
3W 200 AMP	EATON	3MM412RRLB		CMFU, CMOU
3W 200 AMP	EATON	3MM420RRLB		CMFU, CMOU
3W 200 AMP	GE	TMMR2212RHB		CMFU, CMOU
3W 200 AMP	GE	TMMR4220RHB		CMFU, CMOU
3W 200 AMP	GE	TMMR4312RHB		CMFU, CMOU
3W 200 AMP	GE	TMMR4412RHB		CMFU, CMOU
3W 200 AMP	GE	TMMR6320RHB		CMFU, CMOU
3W 200 AMP	GE	TMMR6420RHB		CMFU, CMOU
3W 200 AMP	GE	TMMR6512RHB		CMFU, CMOU
3W 200 AMP	GE	TMMR6520RHB		CMFU, CMOU
3W 200 AMP	GE	TMMR6612RHB		CMFU, CMOU
3W 200 AMP	GE	TMMR6620RHB		CMFU, CMOU
3W 200 AMP	SIEMENS	WMM21125RJB		CMFU, CMOU
3W 200 AMP	SIEMENS	WMM21225RJB		CMFU, CMOU
3W 200 AMP	SIEMENS	WMM31125RJB		CMFU, CMOU
3W 200 AMP	SIEMENS	WMM31225RJB		CMFU, CMOU
3W 200 AMP	SIEMENS	WMM41125RJB		CMFU, CMOU
3W 200 AMP	SIEMENS	WMM41225RJB		CMFU, CMOU
3W 200 AMP	SIEMENS	WMM51125RJB		CMFU, CMOU
3W 200 AMP	SIEMENS	WP2211RJB		CMFU, CMOU
3W 200 AMP	SIEMENS	WP3311RJB		CMFU, CMOU
3W 200 AMP	SIEMENS	WP4212RJB		CMFU, CMOU
3W 200 AMP	SIEMENS	WP4312RJB		CMFU, CMOU
3W 200 AMP	SIEMENS	WP4411RJB		CMFU, CMOU
3W 200 AMP	SIEMENS	WP4412RJB		CMFU, CMOU
3W 200 AMP	SIEMENS	WP4511RJB		CMFU, CMOU
3W 200 AMP	SIEMENS	WP6512RJB		CMFU, CMOU
3W 200 AMP	SIEMENS	WP6611RJB		CMFU, CMOU
3W 200 AMP	SIEMENS	WP6612RJB		CMFU, CMOU
3W 200 AMP	SQUARE D	EZMH112225		CMFU, CMOU

Service	Manufacturer	Part Number	Kit	Service Application
3W 200 AMP	SQUARE D	EZMH113125		CMFU, CMOU
3W 200 AMP	SQUARE D	EZMH113125	RSG4	CMFU, CMOU
3W 200 AMP	SQUARE D	EZMH113225		CMFU, CMOU
3W 200 AMP	SQUARE D	EZMH114125		CMFU, CMOU
3W 200 AMP	SQUARE D	EZMH114225		CMFU, CMOU
3W 200 AMP	SQUARE D	EZMH115125		CMFU, CMOU
3W 200 AMP	SQUARE D	EZMH115225		CMFU, CMOU



Service	Manufacturer	Part Number	Kit	Service Application	Status Date	Comments
3W 200 AMP	ABB	RMS18212HHBR	RM5THJAW	CMFU, CMOU	9/27/2026	
3W 200 AMP	ABB	RMS18212LHBR	RM5THJAW	CMFU, CMOU	9/27/2026	
3W 200 AMP	ABB	RMS18222HHBR	RM5THJAW	CMFU, CMOU	9/27/2026	
3W 200 AMP	ABB	RMS18222LHBR	RM5THJAW	CMFU, CMOU	9/27/2026	
3W 200 AMP	ABB	RMS18312HHBR	RM5THJAW	CMFU, CMOU	9/27/2026	
3W 200 AMP	ABB	RMS18312LHBR	RM5THJAW	CMFU, CMOU	9/27/2026	
3W 200 AMP	ABB	RMS18322HHBR	RM5THJAW	CMFU, CMOU	9/27/2026	
3W 200 AMP	ABB	RMS18322LHBR	RM5THJAW	CMFU, CMOU	9/27/2026	
3W 200 AMP	ABB	RMS18412HHBR	RM5THJAW	CMFU, CMOU	9/27/2026	
3W 200 AMP	ABB	RMS18412LHBR	RM5THJAW	CMFU, CMOU	9/27/2026	
3W 200 AMP	ABB	RMS18422HHBR	RM5THJAW	CMFU, CMOU	9/27/2026	
3W 200 AMP	ABB	RMS18422LHBR	RM5THJAW	CMFU, CMOU	9/27/2026	
3W 200 AMP	ABB	RMS18512HHBR	RM5THJAW	CMFU, CMOU	9/27/2026	
3W 200 AMP	ABB	RMS18512LHBR	RM5THJAW	CMFU, CMOU	9/27/2026	
3W 200 AMP	EATON	1MP3124RRL		CMFU, CMOU	4/13/2027	
3W 200 AMP	EATON	1MP3206RRL		CMFU, CMOU	4/13/2027	
3W 200 AMP	EATON	1MP4124RRL		CMFU, CMOU	4/13/2027	
3W 200 AMP	EATON	1MP4206RRL		CMFU, CMOU	4/13/2027	
3W 200 AMP	EATON	1MP5126RRL		CMFU, CMOU	4/13/2027	
3W 200 AMP	EATON	1MP5206RRL		CMFU, CMOU	4/13/2027	
3W 200 AMP	EATON	1MP6126RRL		CMFU, CMOU	4/13/2027	
3W 200 AMP	EATON	1MP6206RRL		CMFU, CMOU	4/13/2027	
3W 200 AMP	EATON	37MM420R12		CMFU, CMOU	10/3/2026	
3W 200 AMP	EATON	3MM212RRL		CMFU, CMOU	4/13/2027	
3W 200 AMP	EATON	3MM220RRL		CMFU, CMOU	4/13/2027	
3W 200 AMP	EATON	3MM312RRL		CMFU, CMOU	4/13/2027	
3W 200 AMP	EATON	3MM320RRL		CMFU, CMOU	4/13/2027	
3W 200 AMP	EATON	3MM412RRL		CMFU, CMOU	4/13/2027	
3W 200 AMP	EATON	3MM420RRL		CMFU, CMOU	4/13/2027	
3W 200 AMP	SQUARE D	EZMR112225		CMFU, CMOU	4/13/2027	No Horn Bypass
3W 200 AMP	SQUARE D	EZMR113125		CMFU, CMOU	4/13/2027	No Horn Bypass
3W 200 AMP	SQUARE D	EZMR113125	RSG4	CMFU, CMOU	4/13/2027	No Horn Bypass
3W 200 AMP	SQUARE D	EZMR113225		CMFU, CMOU	4/13/2027	No Horn Bypass
3W 200 AMP	SQUARE D	EZMR114125		CMFU, CMOU	4/13/2027	No Horn Bypass
3W 200 AMP	SQUARE D	EZMR114225		CMFU, CMOU	4/13/2027	No Horn Bypass
3W 200 AMP	SQUARE D	MPH33125	MMCBK	CMFU, CMOU	12/31/2026	Manufacturer Discontinued 12/31/2026
3W 200 AMP	SQUARE D	MPH33125	MMCBK & MMLK500	CMFU, CMOU	12/31/2026	Manufacturer Discontinued 12/31/2026
3W 200 AMP	SQUARE D	MPH33125	MMCBK & MMLK600	CMFU, CMOU	12/31/2026	Manufacturer Discontinued 12/31/2026
3W 200 AMP	SQUARE D	MPH33125	MMLK500	CMFU, CMOU	12/31/2026	Manufacturer Discontinued 12/31/2026
3W 200 AMP	SQUARE D	MPH33125	MMLK600	CMFU, CMOU	12/31/2026	Manufacturer Discontinued 12/31/2026

Service	Manufacturer	Part Number	Kit	Service Application	Status Date	Comments
3W 200 AMP	SQUARE D	MPH33125		CMFU, CMOU	12/31/2026	Manufacturer Discontinued 12/31/2026
3W 200 AMP	SQUARE D	MPH42200	MMLK500	CMFU, CMOU	12/31/2026	Manufacturer Discontinued 12/31/2026
3W 200 AMP	SQUARE D	MPH42200	MMLK600	CMFU, CMOU	12/31/2026	Manufacturer Discontinued 12/31/2026
3W 200 AMP	SQUARE D	MPH42200		CMFU, CMOU	12/31/2026	Manufacturer Discontinued 12/31/2026
3W 200 AMP	SQUARE D	MPH43200	MMLK500	CMFU, CMOU	12/31/2026	Manufacturer Discontinued 12/31/2026
3W 200 AMP	SQUARE D	MPH43200	MMLK600	CMFU, CMOU	12/31/2026	Manufacturer Discontinued 12/31/2026
3W 200 AMP	SQUARE D	MPH43200		CMFU, CMOU	12/31/2026	Manufacturer Discontinued 12/31/2026
3W 200 AMP	SQUARE D	MPH55125	MMCBK	CMFU, CMOU	12/31/2026	Manufacturer Discontinued 12/31/2026
3W 200 AMP	SQUARE D	MPH55125	MMCBK & MMLK500	CMFU, CMOU	12/31/2026	Manufacturer Discontinued 12/31/2026
3W 200 AMP	SQUARE D	MPH55125	MMCBK & MMLK600	CMFU, CMOU	12/31/2026	Manufacturer Discontinued 12/31/2026
3W 200 AMP	SQUARE D	MPH55125	MMLK500	CMFU, CMOU	12/31/2026	Manufacturer Discontinued 12/31/2026
3W 200 AMP	SQUARE D	MPH55125	MMLK600	CMFU, CMOU	12/31/2026	Manufacturer Discontinued 12/31/2026
3W 200 AMP	SQUARE D	MPH55125		CMFU, CMOU	12/31/2026	Manufacturer Discontinued 12/31/2026
3W 200 AMP	SQUARE D	MPH64200	MMLK500	CMFU, CMOU	4/13/2027	
3W 200 AMP	SQUARE D	MPH64200	MMLK600	CMFU, CMOU	4/13/2027	
3W 200 AMP	SQUARE D	MPH64200		CMFU, CMOU	4/13/2027	
3W 200 AMP	SQUARE D	MPH66125	MMLK500	CMFU, CMOU	12/31/2026	Manufacturer Discontinued 12/31/2026
3W 200 AMP	SQUARE D	MPH66125	MMLK600	CMFU, CMOU	12/31/2026	Manufacturer Discontinued 12/31/2026
3W 200 AMP	SQUARE D	MPH66125		CMFU, CMOU	12/31/2026	Manufacturer Discontinued 12/31/2026

Service	Manufacturer	Part Number	Kit	Service Application	Status Date	Comments
3W 200 AMP	SQUARE D	MPH85200	MMCBK	CMFU, CMOU	12/31/2026	Manufacturer Discontinued 12/31/2026
3W 200 AMP	SQUARE D	MPH85200	MMCBK & MMLK500	CMFU, CMOU	12/31/2026	Manufacturer Discontinued 12/31/2026
3W 200 AMP	SQUARE D	MPH85200	MMCBK & MMLK600	CMFU, CMOU	12/31/2026	Manufacturer Discontinued 12/31/2026
3W 200 AMP	SQUARE D	MPH85200	MMLK500	CMFU, CMOU	12/31/2026	Manufacturer Discontinued 12/31/2026
3W 200 AMP	SQUARE D	MPH85200	MMLK600	CMFU, CMOU	12/31/2026	Manufacturer Discontinued 12/31/2026
3W 200 AMP	SQUARE D	MPH85200		CMFU, CMOU	12/31/2026	Manufacturer Discontinued 12/31/2026
3W 200 AMP	SQUARE D	MPH86200	MMLK500	CMFU, CMOU	12/31/2026	Manufacturer Discontinued 12/31/2026
3W 200 AMP	SQUARE D	MPH86200	MMLK600	CMFU, CMOU	12/31/2026	Manufacturer Discontinued 12/31/2026
3W 200 AMP	SQUARE D	MPH86200		CMFU, CMOU	12/31/2026	Manufacturer Discontinued 12/31/2026
3W 200 AMP	SQUARE D	MPR33125	MMCBK	CMFU, CMOU	12/31/2026	Manufacturer Discontinued 12/31/2026
3W 200 AMP	SQUARE D	MPR33125	MMCBK & MMLK500	CMFU, CMOU	12/31/2026	Manufacturer Discontinued 12/31/2026
3W 200 AMP	SQUARE D	MPR33125	MMCBK & MMLK600	CMFU, CMOU	12/31/2026	Manufacturer Discontinued 12/31/2026
3W 200 AMP	SQUARE D	MPR33125	MMLK500	CMFU, CMOU	12/31/2026	Manufacturer Discontinued 12/31/2026
3W 200 AMP	SQUARE D	MPR33125	MMLK600	CMFU, CMOU	12/31/2026	Manufacturer Discontinued 12/31/2026
3W 200 AMP	SQUARE D	MPR33125		CMFU, CMOU	12/31/2026	Manufacturer Discontinued 12/31/2026
3W 200 AMP	SQUARE D	MPR42200	MMLK500	CMFU, CMOU	12/31/2026	Manufacturer Discontinued 12/31/2026
3W 200 AMP	SQUARE D	MPR42200	MMLK600	CMFU, CMOU	12/31/2026	Manufacturer Discontinued 12/31/2026

Service	Manufacturer	Part Number	Kit	Service Application	Status Date	Comments
3W 200 AMP	SQUARE D	MPR42200		CMFU, CMOU	12/31/2026	Manufacturer Discontinued 12/31/2026
3W 200 AMP	SQUARE D	MPR43200	MMLK500	CMFU, CMOU	12/31/2026	Manufacturer Discontinued 12/31/2026
3W 200 AMP	SQUARE D	MPR43200	MMLK600	CMFU, CMOU	12/31/2026	Manufacturer Discontinued 12/31/2026
3W 200 AMP	SQUARE D	MPR43200		CMFU, CMOU	12/31/2026	Manufacturer Discontinued 12/31/2026
3W 200 AMP	SQUARE D	MPR55125	MMCBK	CMFU, CMOU	12/31/2026	Manufacturer Discontinued 12/31/2026
3W 200 AMP	SQUARE D	MPR55125	MMCBK & MMLK500	CMFU, CMOU	12/31/2026	Manufacturer Discontinued 12/31/2026
3W 200 AMP	SQUARE D	MPR55125	MMCBK & MMLK600	CMFU, CMOU	12/31/2026	Manufacturer Discontinued 12/31/2026
3W 200 AMP	SQUARE D	MPR55125	MMLK500	CMFU, CMOU	12/31/2026	Manufacturer Discontinued 12/31/2026
3W 200 AMP	SQUARE D	MPR55125	MMLK600	CMFU, CMOU	12/31/2026	Manufacturer Discontinued 12/31/2026
3W 200 AMP	SQUARE D	MPR55125		CMFU, CMOU	12/31/2026	Manufacturer Discontinued 12/31/2026
3W 200 AMP	SQUARE D	MPR64200	MMLK500	CMFU, CMOU	10/3/2026	
3W 200 AMP	SQUARE D	MPR64200	MMLK600	CMFU, CMOU	10/3/2026	
3W 200 AMP	SQUARE D	MPR64200		CMFU, CMOU	10/3/2026	
3W 200 AMP	SQUARE D	MPR66125	MMLK500	CMFU, CMOU	12/31/2026	Manufacturer Discontinued 12/31/2026
3W 200 AMP	SQUARE D	MPR66125	MMLK600	CMFU, CMOU	12/31/2026	Manufacturer Discontinued 12/31/2026
3W 200 AMP	SQUARE D	MPR66125		CMFU, CMOU	12/31/2026	Manufacturer Discontinued 12/31/2026
3W 200 AMP	SQUARE D	MPR85200	MMCBK	CMFU, CMOU	12/31/2026	Manufacturer Discontinued 12/31/2026
3W 200 AMP	SQUARE D	MPR85200	MMCBK & MMLK500	CMFU, CMOU	12/31/2026	Manufacturer Discontinued 12/31/2026
3W 200 AMP	SQUARE D	MPR85200	MMCBK & MMLK600	CMFU, CMOU	12/31/2026	Manufacturer Discontinued 12/31/2026

Service	Manufacturer	Part Number	Kit	Service Application	Status Date	Comments
3W 200 AMP	SQUARE D	MPR85200	MMLK500	CMFU, CMOU	12/31/2026	Manufacturer Discontinued 12/31/2026
3W 200 AMP	SQUARE D	MPR85200	MMLK600	CMFU, CMOU	12/31/2026	Manufacturer Discontinued 12/31/2026
3W 200 AMP	SQUARE D	MPR85200		CMFU, CMOU	12/31/2026	Manufacturer Discontinued 12/31/2026
3W 200 AMP	SQUARE D	MPR86200	MMLK500	CMFU, CMOU	12/31/2026	Manufacturer Discontinued 12/31/2026
3W 200 AMP	SQUARE D	MPR86200	MMLK600	CMFU, CMOU	12/31/2026	Manufacturer Discontinued 12/31/2026
3W 200 AMP	SQUARE D	MPR86200		CMFU, CMOU	12/31/2026	Manufacturer Discontinued 12/31/2026
3W 200 AMP	TALON	WTG2211RJ		CMFU, CMOU	4/13/2027	Discontinued By Manufacturer
3W 200 AMP	TALON	WTG3311RJ		CMFU, CMOU	4/13/2027	Discontinued By Manufacturer
3W 200 AMP	TALON	WTG4411RJ		CMFU, CMOU	4/13/2027	Discontinued By Manufacturer
3W 200 AMP	TALON	WTG6611RJ		CMFU, CMOU	4/13/2027	Discontinued By Manufacturer

Service	Manufacturer	Part Number	Kit	Service Application
3W 200 AMP	MILBANK	U6549-XL-200NF-5T9-IL-LG		CSOO, CSOU, CMOO
3W 200 AMP	MILBANK	U6615-XL-200NF-5T9-IL-LG		CSOO, CSOU, CMOO
3W 400 AMP	MILBANK	U6553-X-400NF-K3L-IL-5T9W		CSOO, CSOU, CMOO
4W 200 AMP	MILBANK	U6550-XL-200NF-IL-LG		CSOO, CSOU, CMOO, CMOU
4W 400 AMP	MILBANK	U6554-X-400NF0K7L-IL		CSOO, CSOU, CMOO, CMOU



Service	Manufacturer	Part Number	Kit	Service Application

Service	Manufacturer	Part Number	Kit	Service Application
	MILBANK	U5136-O-200S-IL-5T9W-EVE		
	MILBANK	U5137-O-100S-IL-5T9W-EVE		
	MILBANK	U5136-O-100S-IL-5T9W-EVE		
	MILBANK	U5137-O-200S-IL-5T9W-EVE		
	MILBANK	U6220-O-200-KK-IL-5T9W-EVE		
	MILBANK	U6220-O-100-KK-IL-5T9W-EVE		
	MILBANK	U6221-O-100-IL-5T9W-EVE		
	MILBANK	U6221-O-200-IL-5T9W-EVE		



Service	Manufacturer	Part Number	Kit	Service Application

Service	Manufacturer	Part Number	Kit	Service Application
3W 400 AMP	MILBANK	KCPLM-413		FIRE PUMP ONLY
3W 400 AMP	MILBANK	KCPLM-413UGBX		FIRE PUMP ONLY
3W 400 AMP	MILBANK	KCPLM-433		FIRE PUMP ONLY
3W 400 AMP	MILBANK	KCPLM-433UGBX		FIRE PUMP ONLY
4W 400 AMP	MILBANK	KCPLM-434		FIRE PUMP ONLY
4W 400 AMP	MILBANK	KCPLM-434UGBX		FIRE PUMP ONLY
4W 400 AMP	MILBANK	KCPLM-434PM		FIRE PUMP ONLY
3W 800 AMP	MILBANK	KCPLM-813		CSOO
3W 800 AMP	MILBANK	KCPLM-813UGBX		RSFU, CSOU
3W 800 AMP	ERICKSON	CT81-KCPL		CSOO
3W 800 AMP	ERICKSON	CT81-KCPL-SG		RSFU, CSOU
3W 800 AMP	MILBANK	KCPLM-833		CSOO
3W 800 AMP	MILBANK	KCPLM-833UGBX		CSOU
3W 800 AMP	ERICKSON	CT83-KCPL		CSOO
3W 800 AMP	ERICKSON	CT83-KCPL-SG		CSOU
4W 800 AMP	MILBANK	KCPLM-834		CSOO
4W 800 AMP	MILBANK	KCPLM-834UGBX		CSOU
4W 800 AMP	MILBANK	KCPLM-834PM		CSOU
4W 800 AMP	ERICKSON	CT84-KCPL		CSOO
4W 800 AMP	ERICKSON	CT84-KCPL-SG		CSOU
4W 800 AMP	ERICKSON	PMCT84-KCPL		CSOU
4W 1200 AMP	MILBANK	KCPLM-1234UGBX		CSOU
4W 1200 AMP	MILBANK	KCPLM-1234PM		CSOU
4W 1200 AMP	ERICKSON	CT124-KCPL-SG		CSOU
4W 1200 AMP	ERICKSON	PMCT124-KCPL		CSOU
4W 1600 AMP	MILBANK	KCPLM-1634UGBX		CSOU
4W 1600 AMP	MILBANK	KCPLM-1634PM		CSOU
4W 1600 AMP	ERICKSON	CT164-KCPL-SG		CSOU
4W 1600 AMP	ERICKSON	PMCT164-KCPL		CSOU
4W 2000 AMP	MILBANK	KCPLM-2034UGBX		CSOU

Service	Manufacturer	Part Number	Kit	Service Application
4W 2000 AMP	MILBANK	KCPLM-2034PM		CSOU
4W 2000 AMP	ERICKSON	CT204-KCPL-SG		CSOU
4W 2000 AMP	ERICKSON	PMCT204-KCPL		CSOU
4W 2500 AMP	MILBANK	KCPLM-2534UGBX		CSOU
4W 2500 AMP	MILBANK	KCPLM-2534PM		CSOU
4W 3000 AMP	MILBANK	KCPLM-3034UGBX		CSOU
4W 3000 AMP	MILBANK	KCPLM-3034PM		CSOU
4W 3000 AMP	ERICKSON	PMCTCC4612N-KCPL		CSOU
4W 4000 AMP	ERICKSON	PMCTCC4613N-KCPL		CSOU

Service	Manufacturer	Part Number	Kit	Service Application